

LOS ANGELES COUNTY FLOOD CONTROL DIST

DEPARTMENTAL MEMORANDUM

April 3, 1943

To: W. B. Ream  
From: W. H. McMillen Re: Dominguez Channel near Avalon Blvd.  
Request to build suspension bridge for pipes.  
Defense Plant Corporation (The Shell Chemical Co.)  
by Stone and Webster Engineering Corpn.

With the exception of the following comments, the proposed work shown on the attached drawing No. FD-158 is satisfactory to this department. This bridge conforms with requirements for "Minimum Relief Plans" but not to "Ultimate Plans."

The elevation governing the clearance between the water surface and the bottom of the proposed bridge is not shown on the preliminary print submitted to us by the Stone Webster Company. This elevation shall not be less than 15.0 U.S.G.S. datum.

WHMcM GB

cc Gen Files

Design ABC

FD 158 = Applicant's Drawing number  
4/5/43 28 FD 35 = FLOOD CONTROL FILING NUMBER

PROOF READ	
Read by	M. B.
Checked by	M. F.
Date	8-26-46